


2020 NFPA 58 UPDATE:

FACE SEAL INSPECTION GUIDE

Does the cylinder valve look like this?



This is a 20 lb cylinder equipped with an OPD valve and a face seal that is in good condition.

YES? THEN YOU NEED TO INSPECT THE FACE SEAL.

These are some examples of damage. If the face seal doesn't look like the one above, or if you are concerned:

DO NOT FILL THE CYLINDER.

Advise the cylinder owner that the cylinder must be removed from service.

Filling Double Seal



Gouging / Tearing



Roping



Cracking



FOR MORE INFORMATION

To learn more about NFPA 58 and the Propane Education & Research Council, visit www.propane.com.

Propane Education & Research Council / 1140 Connecticut Ave. NW, Suite 1075 / Washington, DC 20036
P 202-452-8975 / F 202-452-9054 / propane.com

The Propane Education & Research Council was authorized by the U.S. Congress with the passage of Public Law 104-284, the Propane Education and Research Act (PERA), signed into law on October 11, 1996. The mission of the Propane Education & Research Council is to promote the safe, efficient use of odorized propane gas as a preferred energy source.